



# VIOLATION NOTICE

CITY OF PHILADELPHIA

DEPARTMENT OF LICENSES & INSPECTIONS  
PUBLIC SERVICE CONCOURSE  
MUNICIPAL SERVICES BUILDING, PHILADELPHIA, PA. 19107

APRIL 6, 1989

32687

48 - 60 Laurel Street

PREMISES  
IN  
VIOLATION

Page 3

An inspection of the above premises reveals conditions which are in violation of the Philadelphia Code of General Ordinances, as specified below. Your name appears on official records as the owner, agent or other responsible party for the premises found to be in violation. Failure to correct these conditions within the specified time of this notice will result in prosecution. If title has been transferred please furnish proof of transfer to L & I Central Clerical, Public Service Concourse, Municipal Services Building, 15th Street & J. F. Kennedy Boulevard, Philadelphia, Pa. 19107. The Department does not authorize anyone to solicit any work for services which may be required by this notice.

Violations which do not have a specific location shown apply to the entire premises.

For information on the violations, contact:

Appeal any violation on this notice apply to the Board of License and Inspection Review, Room 710 Municipal Services Building, Philadelphia, Pa. 19107 within 10 days of this notice. It is required to submit a copy of this notice with the appeal.

## SECTION

## VIOLATION

- |               |     |  |
|---------------|-----|--|
| 5-1605(3)(a). | 64  | Provide a separate room enclosed by walls and floor having a fire resistive rating of not less than 3 hours and a ceiling of not less than 2 hours for areas where Class I flammable liquids are mixed or stored.<br>2nd floor - Lab |
| 5-1201(1)     | 66  | Hold fire drills at least once every two months<br>All floors  |
| 5-1201(5)     | 67  | Maintain a record of all fire drills<br>All floors   |
| 5-503(4)      | 120 | Protect combustible floors in chemical storage areas with non-corrosive material.<br>2nd floor   |

100059

B.S.

(Rev. 12/84)